

Portable Water Quality in Office

- Objective:
 - To monitor and improve the drinking water quality in HKSTP Office
- Quality of tap water and boiler water will be tested and analyzed

	Date	Color (HU)	Conductivity (μS/cm)	pH	Turbidity (NTU)	Free residual Chlorine (mg/L)	E Coli (cfu/100mL)	HPC (cfu/mL)	Lead (μg/L)	Cadmium (μg/L)	Chromium (μg/L)	Nickel (μg/L)	Copper (μg/L)	Antimony (μg/L)
		<=5	<=300	>=6.5 and <=9.2	<=3	>0 and <=1.5	0	<=20	<=10	<=3	<=50	<=70	<=2000	<=20
1/F Pantry Water Tap	5/3/2020	√	√	√	√	√	√	√	√	√	√	√	√	√
1/F Pantry Boiler Outlet	5/3/2020	√	√	9.4	√				√	√	√	√	√	√
2/F Pantry Water Tap	5/3/2020	√	√	√	√	√	√	√	√	√	√	√	√	√
2/F Pantry Boiler Outlet	5/3/2020	√	√	√	√				√	√	√	√	√	√
5/F Pantry Near Project Development Water Tap	5/3/2020	√	√	√	√	√	√	√	√	√	√	√	√	√
5/F Lounge Water Tap	5/3/2020	√	√	√	√	√	√	√	√	√	√	√	√	√
5/F Pantry Near IE Team Water Tap	5/3/2020	√	√	√	√	√	√	√	√	√	√	√	√	√
5/F Pantry Near Finance Department Water Tap	5/3/2020	√	√	√	√	√	√	√	√	√	√	√	√	√
5/F Pantry Near Finance Department Boiler Outlet	5/3/2020	√	√	9.4	√				√	√	√	√	√	√
5/F Lounge Boiler Outlet	5/3/2020	√	√	√	√				√	√	√	√	√	√
6/F Pantry Near Cluster Team Water Tap	5/3/2020	√	√	√	√	√	√	√	√	√	√	√	√	√
6/F Pantry Near Investment Team Water Tap	5/3/2020	√	√	√	√	√	√	√	√	√	√	√	√	√
6/F Pantry Near Marketing Department Water Tap	5/3/2020	√	√	√	√	√	√	√	√	√	√	√	√	√
6/F Lounge Water Tap	5/3/2020	√	√	√	√	√	√	√	√	√	√	√	√	√
6/F Lounge Boiler Outlet	5/3/2020	√	√	9.4	√				√	√	√	√	√	√
6/F Pantry Near Investment Team Boiler Outlet	5/3/2020	√	√	√	√				√	√	√	√	√	√

